

ATTENTION

New Procedure – Effective 1/1/09

Subject: **Electrical Service Reconnect**

Procedure:

Commercial properties (includes residential properties with 4 or more units)

Permits can only be issued to licensed contractors

Residential properties:

Permits can be issued to licensed contractors, owners and owners agents
(w/signed affidavit)

Permit fees include 1 inspection – each additional inspection/reinspection will cost \$45.00

The person responsible for the work must be on site at the time of the inspection

Typical violations that must be corrected before the service can be reconnected include:

1. Ground rod missing (5/8” x 8’ galvanized or 1/2” x 8’ copper)
2. Ground wire to water pipe missing
3. Bonding jumper around water meter missing
4. Service entrance cable damaged
5. Equipment rusted (lugs, meter, panel)
6. Service panel not accessible
7. Multiple conductors secured under one lug
8. Overcurrent protection oversized
9. Panel/meter/service entrance cable loose

*60 amp services with violations # 4, 5, 7, or 8 must be upgraded to 100 amps.